

MASKING FRAMES OF HYDRANT VALVES




The masking frames are used as a housings of hydrant valves, which are installed on the end of rising pipe of dry / hydrated vertical section in a high buildings, on each floor.



Standard execution:

- Cabinets made of steel sheet lacquered with [Facade type polyester powder paint](#). The standard color is red (RAL 3000) and white (RAL 9003).
- OTS lock – opened by the fireman's ax in the case of valves provided for in the Regulation of the Ministry of Interior and Administration from June 7, 2010 "on the fire protection of buildings, other buildings and areas".



Symbol	Dimensions [mm] (height/width)
S-MA-400×320-O	400 x 320
S-MA-520×390-O	520 x 390
S-MA-550×550-O	550 x 550

POSSIBILITY OF IMPLEMENTATION



GALVANIZED STEEL SHEET

Lacquered with **Facade** type polyester facade paint. Solution resistant to atmospheric condition and UV radiation



INOX

Stainless steel type 304 with 240 cut or 316L. In aggressive environment (e.g. swimming pools) recommended is only 316L steel



LASER-CUT PATTERN

On the door, using a laser cutter, we can cut any pattern, lettering or logo



PLEXI WINDOW

Window in door protected by plexi



INDIVIDUAL COLOR

Any color from RAL pallet



NON-STANDARD DIMENSIONS

Possible to adopt dimensions to customer request

TYPE OF LOCK



OTS LOCK

Opened by pick-shaped pointed poll of light fire axe

