


INTERNAL HYDRANT DN25 MOUNTED ON THE WALL WITH PLACE FOR FIRE EXTINGUISHER NEXT TO HOSE REEL AND MANOMETER- UNIVERSAL







Internal hydrant DN25 mounted on the wall with 25 mm semi-rigid fire hose. Universal design: possible to connect to water supply as left or right side. Holes for water connection are blanked, enable to connect to water pine 1" or 2", offers six possibilities. of connections: from the side, rear and above. Working pressure from 0,2 to 1,2 MPa. The pressure gauge installed before the valve shows the static pressure in the hydrant installation.





RECESS DIMENSION:

SUPPORTING LEGS: (option) Height: 800 mm Amount: 2 pcs.



Depth: 250 mm

Depth: n/a

Hydrant protected by:

- trademark established by protective law no 185129
- EU industrial design no 001777418-0002
- utility model nr 62999
- utility model nr 64713

Standard design:

- hydrant cabinet STANDARD steel sheet lacquered with <u>Facade type polyester powder paint</u> in red (RAL 3000) or white (RAL 9003) color; thanks to cover hinge cabinet door are opening for 180°
- the pressure gauge installed before the valve shows the static pressure in the hydrant installation. The readable scale of manometer, marked with colors, allows for very fast periodic inspection of hydrants. This is part of routine inspections fulfil by responsible persons between annual inspections and maintenance.
- 25 brass hydrant valve Supron 3 manufacturing
- fire hose reel in RAL 3000 color hinged for 180°, with brass water axis and brake for controlling the unwind force
- φ25 mm semi-rigid fire hose 20 m or 30 m length according to PN-EN 694, fixed connection to water axis by crimping the hose with aluminum sleeve
- hydrant nozzle type PWh-25 according to PN-EN-671-1, fixed connection to fire hose by crimping the nozzle with aluminum sleeve
- valve and water axis connection hose; all thread connections without hose clamps
- Patent lock
- marking: sign "Hydrant" and "Fire Extinguisher" according to PN-EN ISO 7010:2012 + information plate according to PN-EN 671-1
- documentation: instruction of assembly and maintenance
- instruction of change from right to left side
- guarantee card
- identification number

POSSIBILITY OF IMPLEMENTATION

PPUH SUPRON 3 Sp. z o.o. 26-600 Radom, Sadownicza 6

phone: (48) 48 363 89 98 (48) 48 363 99 65 e-mail: export@supron.pl VAT EU: PL9482224948

SWIFT INGBPLPW

IBAN PL 17 1050 1793 1000 0024 0216 9680









GALVANIZED STEEL SHEET

Lacquered with **Facade** type polyester facade paint. Solution resistant to atmospheric condition and UV radiation



INOX

Stainless steel type 304 with 240 cut or 316L. In aggressive environment (e.g. swimming pools) recommended is only 316L steel



LASER-CUT PATTERN

On the door, using a laser cutter, we can cut any pattern, lettering or logo



SAFETY GLASS

Door with matt or transparent glass. Any graphic can be used



PLEXI WINDOW

Window in door protected by plexi



INDIVIDUAL COLOR

Any color from RAL pallet



NON-STANDARD DIMENSIONS

Possible to adopt dimensions to customer request



UNIVERSALITY

Very easy change of the right / left side water connection by rotating the cabinet by 180°. The connection holes are plugged



CONNECTION OF HOSE CONNECTING HYDRANT VALVE WITH WATER AXIS - STANDARD

thread connection in standard connection by adapter and hose coupling



25 VALVE WITH ROTATING ADAPTER - OPTIONAL

thread connection in standard

connection by adapter and hose coupling



NOZZLE CRIMPING

nozzle crimping with aluminum sleeve in standard

nozzle crimping with brass sleeve



52 VALVE WITH SLANT REDUCTION

Hydrant can be connected to DN52 water supply due to 52 valve with slant reduction

PPUH SUPRON 3 Sp. z o.o. 26-600 Radom, Sadownicza 6 phone: (48) 48 363 89 98 (48) 48 363 99 65 e-mail: export@supron.pl VAT EU: PL9482224948

SWIFT INGBPLPW

IBAN PL 17 1050 1793 1000 0024 0216 9680



TYPE OF LOCK



PATENT LOCK

Large quantity of cabinets can be opened with one key. The key for emergency opening is located behind the safety glass.



EURO LOCK

Twist lock adapted to put seal on.