

DECLARATION OF PERFORMANCE

Unique identification code of the product-type: **Internal hydrant with semi-rigid hose type:**

Nr 49/S/CPR/B/ENG - PN-EN 671-2A-3/52-20
 Nr 51/S/CPR/B/ENG - PN-EN 671-2B-1/52-20
 Nr 53/S/CPR/B/ENG - PN-EN 671-2B-1/52-20-G
 Nr 55/S/CPR/B/ENG - PN-EN 671-2B-1/52-20-G vertical version
 Nr 57/S/CPR/B/ENG - PN-EN 671-2B-2/52-20
 Nr 59/S/CPR/B/ENG - PN-EN 671-2B-3/52-20
 Nr 61/S/CPR/B/ENG - PN-EN 671-2B-2/52-20 side version

Nr 50/S/CPR/B/ENG - PN-EN 671-2A-3/52-15
 Nr 52/S/CPR/B/ENG - PN-EN 671-2B-1/52-15
 Nr 54/S/CPR/B/ENG - PN-EN 671-2B-1/52-15-G
 Nr 56/S/CPR/B/ENG - PN-EN 671-2B-1/52-15-G vertical version
 Nr 58/S/CPR/B/ENG - PN-EN 671-2B-2/52-15
 Nr 60/S/CPR/B/ENG - PN-EN 671-2B-3/52-15
 Nr 62/S/CPR/B/ENG - PN-EN 671-2B-2/52-15 side version

Nr 63/S/CPR/B/ENG - PN-EN 671-2C-1/52-20
 Nr 65/S/CPR/B/ENG - PN-EN 671-2C-1/52-20-G
 Nr 67/S/CPR/B/ENG - PN-EN 671-2C-1/52-20-G vertical version
 Nr 69/S/CPR/B/ENG - PN-EN 671-2C-2/52-20
 Nr 71/S/CPR/B/ENG - PN-EN 671-2C-3/52-20

Nr 64/S/CPR/B/ENG - PN-EN 671-2C-1/52-15
 Nr 66/S/CPR/B/ENG - PN-EN 671-2C-1/52-15-G
 Nr 68/S/CPR/B/ENG - PN-EN 671-2C-1/52-15-G vertical version
 Nr 70/S/CPR/B/ENG - PN-EN 671-2C-2/52-15
 Nr 72/S/CPR/B/ENG - PN-EN 671-2C-3/52-15

Intended use/es:

Fixed installations to provide the occupants of a building the means to control and extinguish a fire nearby.

Manufacturer:

PPUH „SUPRON 3” Spółka z o.o., Sadownicza 6, 26-600 Radom, www.supron.pl

System of assessment and verification of constancy of performance: 1

EN 671-2:2012

Harmonised standard:

Notified body/ies:


Centrum Naukowo – Badawcze Ochrony Przeciwpożarowej im. Józefa Tuliszkowskiego Państwowy Instytut Badawczy, notify body no. 1438, performed assessment and verification under system 1 and issued certificate of constancy of performance no. 1438/CPR/0023

Declared performance:

Essential characteristics	Performance	Harmonised technical
DISTRIBUTION OF EXTINGUISHING MEDIA:		
Hose bore	pass	EN 671-2:2012 4.2.1
Minimum flow rate	120 l/min at 0,2 MPa D13	EN 671-2:2012 4.2.2
Effective throw range	pass	EN 671-2:2012 4.2.3
Spray discharge	pass	EN 671-2:2012 4.2.4
OPERATIONAL RELIABILITY:		
Hose - General	pass	EN 671-2:2012 4.3.1
Shut-off nozzle - General	pass	EN 671-2:2012 4.3.2
Shut-off nozzle - Resistance to impact	pass	EN 671-2:2012 4.3.3
Shut-off nozzle – Operating torque	pass	EN 671-2:2012 4.3.4
Inlet stop valve	pass	EN 671-2:2012 4.3.5
Hydraulic properties – Resistance to internal pressure	pass	EN 671-2:2012 4.3.6
Hydraulic properties – Security of couplings	pass	EN 671-2:2012 4.3.7
ABILITY TO PULL OUT THE HOSE		
Type 1	NPD	EN 671-1:2012 4.4.1
Type 1 and Type 3 Reel – Support swinging	pass	EN 671-1:2012 4.4.2
DURABILITY OF OPERATIONAL RELIABILITY		
Resistance to corrosion of coated parts	pass	EN 671-1:2012 4.7.1.1
Resistance to corrosion of waterways	pass	EN 671-1:2012 4.7.1.2
Ageing tests for plastic materials	pass	EN 671-1:2012 4.7.1.3
DANGEROUS SUBSTANCES		
	NPD	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:
Dominika Starzomska wiceprezes zarządu
 (Name and function)

PPUH „SUPRON 3” Spółka z o.o.
 WICEPREZES ZARZĄDU

 mgr inż. Dominika Starzomska

Radom, dn. 01.06.2020 r.
 (Place and date of issue)

(signature)

DECLARATION OF PERFORMANCE

Unique identification code of the product-type: **Internal hydrant with semi-rigid hose type:**

Nr 73/S/CPR/B/ENG - PN-EN 671-2B-3/52-20 W2
Nr 75/S/CPR/B/ENG - PN-EN 671-2B-3/52-20 G4
Nr 77/S/CPR/B/ENG - PN-EN 671-2B-3/52-20 G6
Nr 79/S/CPR/B/ENG - PN-EN 671-2B-3/52-20 side version
Nr 81/S/CPR/B/ENG - PN-EN 671-2B-3/52-20 G4 side version
Nr 83/S/CPR/B/ENG - PN-EN 671-2B-3/52-20 G6 side version
Nr 85/S/CPR/B/ENG - PN-EN 671-2B-1/52-20 side version
Nr 87/S/CPR/B/ENG - PN-EN 671-2B-1/52-20 G4 side version
Nr 89/S/CPR/B/ENG - PN-EN 671-2B-1/52-20 G6 side version

Nr 74/S/CPR/B/ENG - PN-EN 671-2B-3/52-15 W2
Nr 76/S/CPR/B/ENG - PN-EN 671-2B-3/52-15 G4
Nr 78/S/CPR/B/ENG - PN-EN 671-2B-3/52-15 G6
Nr 80/S/CPR/B/ENG - PN-EN 671-2B-3/52-15 side version
Nr 82/S/CPR/B/ENG - PN-EN 671-2B-3/52-15 G4 side version
Nr 84/S/CPR/B/ENG - PN-EN 671-2B-3/52-15 G6 side version
Nr 86/S/CPR/B/ENG - PN-EN 671-2B-1/52-15 side version
Nr 88/S/CPR/B/ENG - PN-EN 671-2B-1/52-15 G4 side version
Nr 90/S/CPR/B/ENG - PN-EN 671-2B-1/52-15 G6 side version

Nr 91/S/CPR/B/ENG - PN-EN 671-2C-3/52-20 W2
Nr 93/S/CPR/B/ENG - PN-EN 671-2C-3/52-20 G4
Nr 95/S/CPR/B/ENG - PN-EN 671-2C-3/52-20 G6
Nr 97/S/CPR/B/ENG - PN-EN 671-2C-3/52-20 side version
Nr 99/S/CPR/B/ENG - PN-EN 671-2C-3/52-20 G4 side version
Nr 101/S/CPR/B/ENG - PN-EN 671-2C-3/52-20 G6 side version
Nr 103/S/CPR/B/ENG - PN-EN 671-2C-1/52-20 side version
Nr 105/S/CPR/B/ENG - PN-EN 671-2C-1/52-20 G4 side version
Nr 107/S/CPR/B/ENG - PN-EN 671-2C-1/52-20 G6 side version

Nr 92/S/CPR/B/ENG - PN-EN 671-2C-3/52-15 W2
Nr 94/S/CPR/B/ENG - PN-EN 671-2C-3/52-15 G4
Nr 96/S/CPR/B/ENG - PN-EN 671-2C-3/52-15 G6
Nr 98/S/CPR/B/ENG - PN-EN 671-2C-3/52-15 side version
Nr 100/S/CPR/B/ENG - PN-EN 671-2C-3/52-15 G4 side version
Nr 102/S/CPR/B/ENG - PN-EN 671-2C-3/52-15 G6 side version
Nr 104/S/CPR/B/ENG - PN-EN 671-2C-1/52-15 side version
Nr 106/S/CPR/B/ENG - PN-EN 671-2C-1/52-15 G4 side version
Nr 108/S/CPR/B/ENG - PN-EN 671-2C-1/52-15 G6 side version

Intended use/es:

Fixed installations to provide the occupants of a building the means to control and extinguish a fire nearby.

Manufacturer:

PPUH „SUPRON 3” Spółka z o.o., Sadownicza 6, 26-600 Radom, www.supron.pl

System of assessment and verification of constancy of performance: 1

Harmonised standard:

EN 671-2:2012

Notified body/ies:


Centrum Naukowo – Badawcze Ochrony Przeciwpożarowej im. Józefa Tuliszkowskiego Państwowy Instytut Badawczy, notify body no. 1438, performed assessment and verification under system 1 and issued certificate of constancy of performance no. 1438/CPR/0102

Declared performance:

Essential characteristics	Performance	Harmonised technical
DISTRIBUTION OF EXTINGUISHING MEDIA:		
Hose bore	pass	EN 671-2:2012 4.2.1
Minimum flow rate	120 l/min at 0,2 MPa D13	EN 671-2:2012 4.2.2
Effective throw range	pass	EN 671-2:2012 4.2.3
Spray discharge	pass	EN 671-2:2012 4.2.4
OPERATIONAL RELIABILITY:		
Hose - General	pass	EN 671-2:2012 4.3.1
Shut-off nozzle - General	pass	EN 671-2:2012 4.3.2
Shut-off nozzle - Resistance to impact	pass	EN 671-2:2012 4.3.3
Shut-off nozzle - Operating torque	pass	EN 671-2:2012 4.3.4
Inlet stop valve	pass	EN 671-2:2012 4.3.5
Hydraulic properties - Resistance to internal pressure	pass	EN 671-2:2012 4.3.6
Hydraulic properties - Security of couplings	pass	EN 671-2:2012 4.3.7
ABILITY TO PULL OUT THE HOSE		
Type 1	NPD	EN 671-1:2012 4.4.1
Type 1 and Type 3 Reel - Support swinging	pass	EN 671-1:2012 4.4.2
DURABILITY OF OPERATIONAL RELIABILITY		
Resistance to corrosion of coated parts	pass	EN 671-1:2012 4.7.1.1
Resistance to corrosion of waterways	pass	EN 671-1:2012 4.7.1.2
Ageing tests for plastic materials	pass	EN 671-1:2012 4.7.1.3
DANGEROUS SUBSTANCES		
	NPD	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:
Dominika Starzomska wiceprezes zarządu
 (Name and function)

PPUH "SUPRON 3" Spółka z o.o.
 WICEPREZES ZARZĄDU

 mgr inż. Dominika Starzomska

Radom, dn. 01.06.2020 r.
 (Place and date of issue)

(signature)